

WAKE COUNTY DEPARTMENT OF HEALTH & HUMAN SERVICES WELL PERMIT

***PERMIT VOID IF NOT IN COMPLIANCE WITH ZONING REGULATIONS AND/OR IF SITE IS ALTERED
OR INTENDED USE CHANGED***

WELL CONSTRUCTION AUTHORIZATION

PERMIT #: GW-154504-2025

APPLICATION DATE: 09/01/2025

SITE INFORMATION:

PIN: 1801023952

SITE ADDRESS: 7408 JADINS WAY
RALEIGH, 27614

SUBDIVISION: MARLANE KLINTWORTH

LOT: 4

ACRES: 2

TOWNSHIP: 02 - Bartons Creek

JURISDICTION: R-80W

ZONING:

APPLICANT: Chris W Stacy

PHONE NUMBER: (540) 840-1901

OWNER:

PROPOSED USE:

EXISTING USE:

PERMIT CONDITIONS & COMMENTS:

A review of GIS datasets of known contamination sites revealed one or more known contamination sites within 1500 ft of the subject parcel or subject historical activities. Additional testing of this well for Volatile Organic Compounds (VOCs) will be required for final approval of this water supply.

Well to be drilled in area listed. Well must be a minimum of 50' from any septic system or existing well, 25' from any building perimeter and 10' from any property line.

OTHER CONDITIONS:

SCOPE: SATISFIED?:

COMMENTS:

See attached site plan for well location and wastewater system design. If changes are necessary, prior approval by Wake County Health & Human Services is required before installation. The testing required under this permit does not include all possible contaminants. Private wells are not routinely monitored by a utility or other agency. Continued monitoring of private wells and testing for contaminants other than those required for the certificate of completion or certificate of occupancy is the responsibility of the well owner. Neither Wake County nor the Environmental Health Specialist warrants the quantity or quality of water produced by this well

This construction authorization permit expires on 09/18/2030.


PERMIT ISSUED: 09/19/2025

ISSUED BY: Brian Wall


SIGNATURE:



7408 Jadins Way
Lot 4
4 BR
Wake County



Adams
Soil Consulting
919-414-6761



INITIAL:
Lines 3-6 (400')
Accepted Status
Gravity Parallel
REPAIR:
Lines 1-2,7-8 (270')
PPBPS
Pressure Manifold