

Environmental Services - Water Quality
Onsite Wastewater Scan Data Entry Form

PERMIT #: C014211

PIN #: 0676029425

OP DATE: 0412411992

SYSTEM USE:

- ☒ House
☐ Mobile Home
☐ Business
☐ Other

SEWAGE TYPE:

- ☒ Domestic
☐ Industrial

PUMP/SIPHON?:

- ☐ Yes
☒ No

PRESSURE MANIFOLD:

- ☐ Yes
☒ No

SYSTEM TYPE:

- ☐ I
☒ II
☐ III
☐ IV
☐ V
☐ VI
☐ Other

SUB TYPE:

- ☒ A
☐ B
☐ C
☐ D
☐ E
☐ F
☐ G

NBR BEDROOMS:

- ☐ 1
☐ 2
☒ 3
☐ 4
☐ 5
☐ 6
☐ Other

MAINT. SCHEDULE:

- ☐ Yes
☒ No

CERT. OPERATOR

- ☐ Yes
☒ No

GT ST PT SIZE

- | | | | |
|-------------------------------------|-------------------------------------|-------------------------------------|------------------|
| ☐ | ☐ | ☐ | 750 |
| ☐ | ☐ | ☐ | 900 |
| ☐ | ☒ | ☐ | 1,000 |
| ☐ | ☐ | ☐ | 1,200 |
| ☐ | ☐ | ☐ | 1,500 |
| ☐ | ☐ | ☐ | 1,800 |
| ☐ | ☐ | ☐ | 2,100 |
| ☐ | ☐ | ☐ | 2,500 |
| ☐ | ☐ | ☐ | 3,000 |
| ☐ | ☐ | ☐ | 4,000 |
| ☐ | ☐ | ☐ | 5,000 |
| ☐ | ☐ | ☐ | 8,000 |
| ☐ | ☐ | ☐ | 10,000 |
| ☐ | ☐ | ☐ | Other |
| ☒ | | ☒ | None/NA GT or PT |

DRAINFIELD SIZE(SQ. FT.)

00960

DRAIN TYPE:

- ☒ Stone
☐ EZ Flow
☐ Infiltrator
☐ Biodiffuser
☐ Cultec
☐ Drip
☐ Hancor
☐ Large Dia. Pipe
☐ Multi-Pipe
☐ Other

MAX DEPTH (IN.):

- ☐ 12 in. or less
☐ 18 in. or less
☐ 24 in. or less
☐ 26 in. or less
☐ 28 in. or less
☒ 30 in. or less
☐ 32 in. or less
☐ 36 in. or less
☐ Other

STONE DEPTH (IN.):

- ☐ 8 in. or less
☒ 12 in. or less
☐ 18 in. or less
☐ 24 in. or less
☐ Other

TRENCHES:

- ☒ Individual
☐ Bed

TRENCH WIDTH (IN.):

- ☐ 12 in. or less
☐ 18 in.
☐ 24 in.
☐ 36 in.
☐ 6 ft. or less
☐ 9 ft. or less
☒ Other

WAKE COUNTY HEALTH DEPARTMENT WELL AND SEWAGE SITE, LOCATION PERMIT

ALL PERMITS VOID 60 MONTHS FROM DATE OF ISSUANCE

Tax Map No. 867 Parcel No. 81482

Improvement Permit
Well Permit No. **C 14211**

Zoning Wake Township Middle Creek

Operation Permit []

Owner/Contractor: Randall Shirley

Date: April 4, 1992


Location/Address: 3405 Apple Meadow Dr.

S.R. # 2766

Subdivision Name: Holland Crossing

Lot No. 20421

Section or Block No. _____



Final Layout

Sewage System Specifications

Repair [] Original Permit No. _____

Garbage Disposal Unit Yes [] No [X]

House [X] Mobile Home [] Business []

No. of Bedrooms 3 Lot Area _____

Size of Tank 1000 gal.

Comments: _____

Nitrification Line 2(3' x 160') ~~400~~ 960 sq. ft.

Depth of Stone: 12" [X] Max Depth of Trenches: 30 in.

Riser and Baffle Required [X] Pump Required []

Permit void if not in compliance with zoning regulations

Permits may be voided if site is altered or intended use changed

Layout by: Robert S. Fletcher, P.E.

Date: 4-24-92

Installed By: Joel Power

Approved By: W. David Brown, P.E.

Well System
Individual [X] Semi-Public [] Public []
New [X] Replacement [] Repair []
Fee Paid: Yes [X] No []

Construction Compliance
Site Approved [X] Yes [] No []
Well Head Approved [X]
Grouting Approved [X]

Date Inspected 6/5/92

Sanitarian Joel Power

Final Inspection

	Yes	No
Required Slab	[X]	[]
Chlorinated	[X]	[]
Required Certificate	[]	[]
Variance (Explain)	[]	[X]
WCHD I.D. Affixed <u>3037</u>	[X]	[]
Sample Collected	[X]	[]

Comments: _____

Bacteriological Results
Initial Sample: pos. Date: 7/24/92
* Re-Sample #1 pos. Date: 7/30/92
* Re-Sample #2 neg. Date: 8/31/92
* Re-chlorination as required [] Yes [] No
* Fees for all resamples

All checks payable to: **Wake County Health Department**

Well Installed By: Estes Well
8/5/92 Date System Finalized
Joel Power Sanitarian

This report is based in part on information provided by the homeowner or his/her representative in the application submitted for this permit. The sanitarian is not responsible for false or misleading information contained in the application. The sanitarian is also not responsible for concealed conditions on the property or for statements in this report that may have resulted from false or misleading statements provided to him in the application. Neither Wake County nor the sanitarian warrants that the septic tank system will continue to function satisfactorily in the future or that the water supply will remain potable.

COPY TO HEALTH DEPARTMENT

Tax Map No. 867

Parcel No. 81482