

WAKE COUNTY DEPARTMENT OF HEALTH & HUMAN SERVICES WELL PERMIT

***PERMIT VOID IF NOT IN COMPLIANCE WITH ZONING REGULATIONS AND/OR IF SITE IS ALTERED
OR INTENDED USE CHANGED***

WELL CONSTRUCTION AUTHORIZATION

PERMIT #: GW-169683-2026

APPLICATION DATE: 04/25/2026

SITE INFORMATION:

PIN: 0798183010

SITE ADDRESS: 10008 WATERFORD CT
RALEIGH, 27613

SUBDIVISION: VAN HART HOMES SUBDIV **LOT:** 2 **ACRES:** 2

TOWNSHIP: 08 - Leesville **JURISDICTION:** R-40W **ZONING:**

APPLICANT: Mark Ward **PHONE NUMBER:** (919) 614-7600

OWNER:

PROPOSED USE: 0006 NEW WELL

EXISTING USE:

PERMIT CONDITIONS & COMMENTS:

A review of GIS datasets revealed one or more buildings built between the years 1948 and 1987 within 150 feet of the subject parcel. Additional testing of this well for Pesticides will be required for final approval of this water supply.

Well is to be drilled in area listed. Well area is 40' off of adjacent property lines, 51' off of front property line, and 25' from building perimeter. Well can not be drilled in tree protection zone.

Driller is to verify all setbacks in the field before drilling.

OTHER CONDITIONS:

:

Variance Issued?: - No

SCOPE: SATISFIED?:

COMMENTS:

See attached site plan for well location and wastewater system design. If changes are necessary, prior approval by Wake County Health & Human Services is required before installation. The testing required under this permit does not include all possible contaminants. Private wells are not routinely monitored by a utility or other agency. Continued monitoring of private wells and testing for contaminants other than those required for the certificate of completion or certificate of occupancy is the responsibility of the well owner. Neither Wake County nor the Environmental Health Specialist warrants the quantity or quality of water produced by this well

This construction authorization permit expires on 05/03/2031.


PERMIT ISSUED: 05/04/2026

ISSUED BY: Brian Wall

SIGNATURE:

Barry Hall

WATERFORD COURT 60' PUBLIC R/W



Well is to be drilled in area listed. Well area is 40' off of adjacent property lines, 51' off of front property line, and 25' from building perimeter. Well can not be drilled in tree protection zone.

Driller is to verify all setbacks in the field before drilling.

LOT 2 (10008 WATERFORD CT)

5-BEDROOM GRAVITY TO SERIAL SYSTEM
LINES 6-9 (502')
EZFLOW OR CHAMBERS
LTAR 0.3
18" TRENCH BOTTOM

5-BEDROOM PRESSURE MANIFOLD REPAIR
LINES 1-5 (668')
EZFLOW OR CHAMBERS
LTAR 0.3
18" TRENCH BOTTOM

FOR GENERAL USE NOT A SURVEY
PRELIMINARY NOT FOR CONSTRUCTION

System:
Repair:
Repair: #1

LINE SCHEDULE SYSTEM				
LINE NUMBER	COLOR	FIELD ELEVATION	LENGTH	DESIGN LENGTH
1	PINK	1.6	135	
2	YELLOW	2.2	134	
3	PURPLE	2.7	134	
4	RED	3.1	133	
5	GREEN	4.1	132	
6	BLUE	4.6	153	153
7	ORANGE	5.2	133	133
8	PINK	6.0	120	120
9	YELLOW	6.6	96	96



SCALE:
1" = 60 ft.



Central Carolina Soil Consulting, PLLC
1904 South Main Street, Suite 116
Wake Forest, North Carolina 27587
Phone (919)569-6704 Fax (919)569-6703

Septic System Layout
Lot 2 10008 Waterford Ct
Raleigh, Wake County, North Carolina

Job# : 3826
Drawn By : MB
Date : 04/13/2026
Revision: