



BACTERIOLOGICAL WATER ANALYSIS REPORT
Wake County Human Services Laboratory
10 Sunnybrook Rd., Raleigh, NC 27610
(919) 250-4437 Certification #37503

Collection Site of Water Sample:

3336 Holly Lake Trl

Collection Date: 02/26/2024

Collection Time: 10:59 AM

Collection Point: wellhead

Collected By: Customer

Lab Number: 24022601-01

Permit: fdj123@aol.com
WS-119531-2024

Results:

E. coli	Absent
Total coliform	Absent

Report Date: 02/27/2024

Reported By: *Kimberly Trossman*

Kimberly Trossman

Environmental Health Manager

All samples are free of residual chlorine prior to analysis.

Total Coliform is a group of related bacteria that are (with few exceptions) not harmful to humans. Total coliforms are used to determine the adequacy of water treatment and the integrity of the distribution system. If Total Coliform is Present, it is recommended that your well water be re-tested to verify that the result is accurate.

If e. coli (fecal) is Present do not use the water for drinking, cooking, washing dishes, bathing or showering.