

WAKE COUNTY DEPARTMENT OF ENVIRONMENTAL SERVICES WASTEWATER PERMIT

NO PERMIT(S) FOR CONSTRUCTION, LOCATION OR RELOCATION ACTIVITY SHALL BE ISSUED UNTIL AN AUTHORIZATION FOR WASTEWATER SYSTEM CONSTRUCTION AUTHORIZATION HAS BEEN ISSUED

PERMIT VOID IF NOT IN COMPLIANCE WITH ZONING REGULATIONS AND/OR IF SITE IS ALTERED OR INTENDED USE CHANGED

OPERATIONS PERMIT

PERMIT # WREP-134188-2024

APPLICATION DATE: 10/14/2024

BLDG. PERMIT#:

PIN: 1729576558

RECORDED: Yes

TOWNSHIP: 19 - Wake Forest

JURISDICTION: Wake County

ZONING: R-30

APPLICANT: Jill Gillchrist
6109 RIVERSIDE DR

BUSINESS PHONE:

HOME PHONE:

MOBILE PHONE: (919) 453-3501

HD USE: 0001 REPAIR/EXISTING SYSTEM

EXISTING USE: 101A CONVENTIONAL ONE-FAMILY HOUSE

SITE ADDRESS: 6109 RIVERSIDE DR

SUBDIVISION: HIGHLAND PARK

LOT: 18

ACRES: 1.61

DIRECTIONS: FALLS OF THE NEUSE RD; TL OLD FALLS OF THE NEUSE RD; TR RIVERSIDE DR; PROPERTY ON RIGHT AT 6109 RIVERSIDE DRIVE.

Systems defined as either type III-b, III-g with a pump, IV, V or VI, in accordance with the North Carolina administrative code 15A NCAC 18a .1961, table V as adopted by reference in the "Regulations Governing Wastewater Treatment Dispersal Systems in Wake County", requires Wake County Environmental Services to conduct periodic inspections of the system type pursuant to 15A NCAC 18a. 1961 (j). Fees for these inspections will be charged as per the approved Fee Schedule. In addition, all systems are to be operated and maintained as specified in 15A NCAC 18A .1961. This permit is based in part on information provided by the homeowner and/or his/her representative in the application submitted for this permit. The Environmental Health Specialist is not responsible for false or misleading information contained in the application. The environmental health specialist is also not responsible for concealed conditions on the property or for statements in this report that may have resulted from false or misleading statements provided to him/her in the application. Neither Wake County nor the Environmental Health Specialist warrants that the septic tank system will continue to function satisfactorily in the future or that the water supply will remain potable.

OPERATION PERMIT VALID FOR: No Expiration

INSTALLED BY: OTHER

PROPRIETARY SYSTEM: TANK - Septic/Pump Tank
Replacement

PRETREATMENT SYSTEM:

SYSTEM TYPE INSTALLED:

OPERATION PERMIT: STATUS: Issued

ISSUED BY: Tim Warren

ISSUED DATE: 11/01/2024

SEPTIC TANK: David Brantley & Sons - STB-322 - 1500 gallons

DATE OF MANUFACTURE: 08/01/2024

FILTER: Polylok - PL-68

GREASE TRAP:

DATE OF MANUFACTURE:

FILTER:

DOSING PUMP TANK:

DATE OF MANUFACTURE:

FILTER:

CC1: ETM1:

CC2:

ETM2:

RECIRCULATION TANK:

DATE OF MANUFACTURE:

CC1: ETM1:

CC2:

ETM2:

SEPTIC TANK ELEVATION: 5.75

GREASE TRAP ELEVATION:

DOSING PUMP TANK ELEVATION:

RECIRCULATION TANK ELEVATION:

DISTRIBUTION DEVICE ELEVATION: 9

INSTALLED TRENCH DEPTH	INSTALLED AGGREGATE DEPTH	INSTALLED TRENCH LENGTH	INSTALLED TRENCH BOTTOM ELEVATION

ACTUAL PRESSURE HEAD:

ACTUAL FLOW RATE:


ACTUAL DOSE VOLUME: 0

SPECIFIC OPERATION REQUIREMENTS:
OPERATION PERMIT ISSUED FOR A 5 BEDROOM HOME WITH A DAILY FLOW RATE OF 600 GALLONS PER DAY AND MAXIMUM OCCUPANCY 10 PERSONS.

ISSUED BY:




DATE: 11/01/2024



6109 RIVERSIDE DR

11/01/2024
JTW



Disclaimer
Mapmaker makes every effort to produce and publish the most current and accurate information possible. However, the maps are produced for information purposes, and are NOT surveys. No warranties, expressed or implied, are provided for the data therein, its use, or its interpretation.