

* Neither State nor local Health Dept. shall be liable for any damages caused by an engineered system approved or permitted pursuant to session law 2014-120 Sec. 53

PERMIT NUMBER **8296**

GRANVILLE-VANCE DISTRICT HEALTH DEPARTMENT IMPROVEMENT AND OPERATION PERMITS

COUNTY:	TAX NO.	TYPE OF ESTABLISHMENTS			*THIS PERMIT SHALL BE ACCOMPANIED BY A LAYOUT SHOWN ON A PLAT, INCLUDING SYSTEM REQUIREMENTS.
<i>Granville</i>	SR. NO.	RESIDENCE ☒ BUSINESS ☐ OTHER ☐	NUMBER OF BEDROOMS: <i>34</i>	NUMBER OF OCCUPANTS: <i>60</i>	
OWNER: <i>Savvy Home, LLC</i>		WATER SUPPLY	WELL ☒ PUBLIC ☐	OTHER ☐	*THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF THE INTENDED USES CHANGE FROM THOSE SHOWN ON THE IMPROVEMENT PERMIT. CHANGES SHALL REQUIRE HEALTH DEPARTMENT APPROVAL.
APPLICANT'S ADDRESS: <i>8005 Creedmoor Rd, Suite 100 Raleigh, NC 27613</i>		TYPE OF WASTEWATER SYSTEM	INITIAL INSTALLATION <i>Yes</i>	REPAIR	
PROPERTY ADDRESS/LOCATION: <i>1708 Ripple Ct</i>		DESIGN FLOW:	<i>360 GPD</i>		
SUBDIVISION: <i>Fronwood</i>		LTAR:	<i>13 GPD/ft²</i>		
LOT NUMBER: <i>63</i>		ABSORPTION AREA:	<i>1300 ft²</i>		
REFERENCE SKETCH (SEE PLAT FOR DETAILS)		TRENCH WIDTH:	<i>3'</i>		
		TRENCH DEPTH:	<i>24"</i>	<i>18"</i>	
		TRENCH SPACING:	<i>9' O.C.</i>		
		TOTAL TRENCH LENGTH:	<i>325' approx</i>		
		NUMBER OF TRENCHES:	<i>3</i>		
		GRAVEL DEPTH:	<i>NA</i>		
		TANK SIZE:	<i>1000 Gallon</i>		
	PUMP TANK SIZE:	<i>1000 Gallon</i>		PERMIT VALID FOR: 5 YEARS ☒ YES ☐ NO	
	DISTRIBUTION DEVICE:	<i>Pressure Main</i>		NO EXPIRATION ☐ YES ☒ NO	

IMPROVEMENT PERMIT DATE: *8/28/15*

FOR: *Savvy Home*
ISSUED BY: *Ali Hill*

CONSTRUCTION AUTHORIZATION FOR IMPROVEMENT PERMIT# *8296*

Unless otherwise indicated, the same conditions above apply regarding system type, layout, location and installation requirements.
(The wastewater system cannot be installed until authorization is signed)

Comments: *Installed according to attached plan*

Date: *8/28/15* Environmental Health Specialist: *Ali Hill*

Construction Authorization Addendum ☒ Yes ☐ No

OPERATION PERMIT

DATE: *11-21-16* / *10/5/20*

SYSTEM INSTALLED BY: *Glenn Todd*
ISSUED BY: *Ali Hill*

*Owner did flow reduction
see attached
packet (WTS)*

PERFORMANCE, MONITORING, MAINTENANCE AND OPERATION
AS REQUIRED BY RULE .1961