

WAKE COUNTY DEPARTMENT OF ENVIRONMENTAL SERVICES WASTEWATER PERMIT

NO PERMIT(S) FOR CONSTRUCTION, LOCATION OR RELOCATION ACTIVITY SHALL BE ISSUED UNTIL AN
AUTHORIZATION FOR WASTEWATER SYSTEM CONSTRUCTION AUTHORIZATION HAS BEEN ISSUED
***PERMIT VOID IF NOT IN COMPLIANCE WITH ZONING REGULATIONS AND/OR IF SITE IS ALTERED OR
INTENDED USE CHANGED***

OPERATIONS PERMIT

PERMIT # WREP-086144-2022

APPLICATION DATE: 08/03/2022

BLDG. PERMIT#:

PIN: 1719450118

RECORDED: Yes

TOWNSHIP: 02 - Bartons Creek

JURISDICTION: Wake County

ZONING: R-80W

APPLICANT: Jeffrey LaRose
5420 DEER FOREST TRL

BUSINESS PHONE:

HOME PHONE:

MOBILE PHONE:

HD USE: 0001 REPAIR/EXISTING SYSTEM

EXISTING USE: 101A CONVENTIONAL ONE-FAMILY HOUSE

SITE ADDRESS: 5420 DEER FOREST TRL

SUBDIVISION: STONEFIELD SUB

LOT: 7

ACRES: 4.25

DIRECTIONS: TAKE FALLS OF NEUSE RD NORTH. TURN LEFT ONTO DURANT RD. TURN RIGHT ONTO HONEYCUTT RD. TURN RIGHT ONTO DEER FOREST TRAIL. HOUSE ON LEFT.

Systems defined as either type III-b, III-g with a pump, IV, V or VI, in accordance with the North Carolina administrative code 15A NCAC 18a .1961, table V as adopted by reference in the "Regulations Governing Wastewater Treatment Dispersal Systems in Wake County", requires Wake County Environmental Services to conduct periodic inspections of the system type pursuant to 15A NCAC 18a. 1961 (j). Fees for these inspections will be charged as per the approved Fee Schedule. In addition, all systems are to be operated and maintained as specified in 15A NCAC 18A .1961. This permit is based in part on information provided by the homeowner and/or his/her representative in the application submitted for this permit. The Environmental Health Specialist is not responsible for false or misleading information contained in the application. The environmental health specialist is also not responsible for concealed conditions on the property or for statements in this report that may have resulted from false or misleading statements provided to him/her in the application. Neither Wake County nor the Environmental Health Specialist warrants that the septic tank system will continue to function satisfactorily in the future or that the water supply will remain potable.

OPERATION PERMIT VALID FOR: No Expiration

INSTALLED BY: HEFLIN, KENNITH D - 4867 - II

PROPRIETARY SYSTEM: EZ1203HG - EZFlow EZ 1203H Geo **PRETREATMENT SYSTEM:**

SYSTEM TYPE INSTALLED: III B

OPERATION PERMIT: STATUS: Issued

ISSUED BY: Tim Warren

ISSUED DATE: 11/03/2022

SEPTIC TANK: EXISTING

DATE OF MANUFACTURE:

FILTER:

GREASE TRAP:

DATE OF MANUFACTURE:

FILTER:

DOSING PUMP TANK: Infiltrator - IM-1060 -
1287 gal - Variable gal/in

DATE OF MANUFACTURE:

FILTER:

CC1: 999966

ETM1: 0.14

CC2:

ETM2:

RECIRCULATION TANK:

DATE OF MANUFACTURE:

CC1:

ETM1:

CC2:

ETM2:

SEPTIC TANK ELEVATION:

GREASE TRAP ELEVATION:

DOSING PUMP TANK ELEVATION: 5.85

RECIRCULATION TANK ELEVATION:

DISTRIBUTION DEVICE ELEVATION: 1

INSTALLED TRENCH DEPTH	INSTALLED AGGREGATE DEPTH	INSTALLED TRENCH LENGTH	INSTALLED TRENCH BOTTOM ELEVATION
24	12	100	5.91
24	12	100	5.2
24	12	100	4.91
24	12	100	4.5

ACTUAL PRESSURE HEAD: 2

ACTUAL FLOW RATE: 29

ACTUAL DOSE VOLUME: -167

SPECIFIC OPERATION REQUIREMENTS:

OPERATION PERMIT IS FOR A 4 BR HOME WITH DAILY FLOW RATE OF 480 GALLONS PER DAY

ISSUED BY:



DATE: 11/03/2022




OPERATION PERMIT

AS BUILT

REPAIR

WREP-086144-2022

5420 Deer Forest As Built Drawing



Disclaimer
Maps makes every effort to produce and publish the most current and accurate information possible. However, the maps are produced for information purposes, and are NOT surveys. No warranties, expressed or implied, are provided for the data therein, its use, or its interpretation.