

Report on 05/07/2026 04:29 PM

Recurring Test

Customer Information

KAREN DAVIS
1121 CAPITATA XING
Apex, NC 27502
APX0282455



Tester Information

Scott Smith-Martinez
License #: RWCT3194
License Expiration: 2026-11-01
Raleigh Backflow Guy
650 W North St #333
Raleigh, NC 27603

Backflow Information

Type: RP
Manufacturer: Wilkins
Model: 975XL
Size: 1"
Serial #: W004617
Category: Irrigation
Location: HOTBOX RIGHT SIDE OF HOUSE

Purveyor Information

Town of Apex Water Resources
NC0392045
Jessica Sloan
(919) 372-7478
PO Box 250
Apex, NC 27502

Passed

Is the backflow installed in accordance with manufacturer recommendations and/or local codes?

Yes	No
☒	☐

Test Results

Check Valve #1		
9.60 PSID		
Closed Tight		
Check Valve #2		
3.00 PSID		
Closed Tight		
Relief Valve & Buffer		
Relief Valve: 2.50 PSI	Buffer: 7.10 PSID	
Shutoff Valves		
Shutoff #1: Closed Tight	Shutoff #2: Closed Tight	
Line Pressure		
110.00 PSI		
Pressure Gauge Used		
Manufacturer: Midwest	Model: 845-5	Potable ☒
SN: 10162033	Calibration Date: 2025-06-20	Non-Potable ☐
Report Notes		
No Notes		