

WAKE COUNTY HEALTH DEPARTMENT WELL AND SEWAGE SITE, LOCATION PERMIT

ALL PERMITS VOID 60 MONTHS FROM DATE OF ISSUANCE

Tax Map No. 331 Parcel No. 174

Zoning Wake Township Wake Forest

Owner/Contractor: Nancy Watkins

Improvement Permit

Well Permit No. **C 16664**

Operation Permit []

Date: 4-27-93



Location/Address: (4141 Stell Dr.) 401 N, (R) Mitch. Mill Rd, (L) at 4325 Mitch. Mill Rd, Follow path beside House, lot on it.

S.R. # 2225

Subdivision Name:

Lot No.

Section or Block No.



Sewage System Specifications

Repair [] Original Permit No.

Garbage Disposal Unit Yes [] No [☒] Mills 1000

House [] Mobile Home [☒] Business []

No. of Bedrooms 3 Lot Area 10.0 AC

Size of Tank 1000 gal.

Nitrification Line 1000 ft² 2(3'x16') sq. ft.

Depth of Stone: 12" [☒] Max Depth of Trenches: 30 in.

Riser and Baffle Required [☒] Pump Required []

Permit void if not in compliance with zoning regulations

Permits may be voided if site is altered or intended use changed

Layout by: Terry D. Chappell R.S.

* Comments: Keep system shallow, Follow contours, stay 10' min from prop. line.

Date: 5-6-93 Installed By: Joel Powell Approved By: DR Parnell

Well System

Individual [☒] Semi-Public [] Public []

New [☒] Replacement [] Repair []

Fee Paid: Yes [☒] No []

Construction Compliance Yes [] No []

Site Approved [] []

Well Head Approved [] []

Grouting Approved [] []

Final Inspection

	Yes	No
Required Slab	[]	[]
Chlorinated	[]	[]
Required Certificate	[]	[]
Variance (Explain)	[]	[]
WCHD I.D. Affixed	[]	[]
Sample Collected	[]	[]

Bacteriological Results

Date Inspected Sanitarian

Initial Sample: Date:

* Re-Sample #1 Date:

* Re-Sample #2 Date:

* Re-chlorination as required [] Yes [] No

* Fees for all resamples

All checks payable to: **Wake County Health Department**

Comments:

Well Installed By:

Date System Finalized Sanitarian

This report is based in part on information provided by the homeowner or his/her representative in the application submitted for this permit. The sanitarian is not responsible for false or misleading information contained in the application. The sanitarian is also not responsible for concealed conditions on the property or for statements in this report that may have resulted from false or misleading statements provided to him in the application. Neither Wake County nor the sanitarian warrants that the septic tank system will continue to function satisfactorily in the future or that the water supply will remain potable.

COPY TO HEALTH DEPARTMENT

1984