



**14.1.2 & 14.2.1 Per seller:** well head and crawlspace wiring corrected. Put the exposed wiring in a weatherproof box and in flexible conduit. Cleared around the foundation and put the birdbath cover back in place. In crawlspace, put the wiring in a new junction box and attached to a beam to keep it off the ground.







7.3.1 - screw added



7.6.1 - cover plate  added



7.6.4 - cover added



7.6.2 - light is operable



2.6.4 - door is operable



Septic report- removed lattice to access the distribution manifold



4.4.1 - roof ridgeline supprted by JCF Construction, Inc.





Radon system installed and paid invoice in documents