



City of Raleigh
Inspections Department



RECEIPT

Receipt #: 252175

Payment Date: 2/18/2011

Payor: KIM FITZSIMMONS
5005 DENHAM CT
RALEIGH, NC 27613

Payment:

Visa - \$74.00

Total Payment - \$74.00

Group #: 245336 Trans #: 294761 5005 DENHAM CT

PL 93519

\$74.00

\$74.00

\$74.00

Cashier: SPRINGB _____

City of Raleigh - Inspection Data

Approvals shall be obtained through each phase of applicable inspections, prior to subsequent work in next phase. Inspections will be made as soon as practical, however work shall not progress or be covered until the applicable inspection has been approved and card signed.

INSPECTION REQUEST The contractor performing the work must call for all inspections. Requests for inspections must be made the business day prior to the day of the requested inspection. To request an inspection, please call (919) 516-2500 by 4pm of the working day prior to the inspection date or telephone our Rapid Response (automated scheduling) line at (919) 857-4412 the business day prior to the day of the requested inspection. Inspections Department approved plans including a site/plot plan must be on the project site before work can be inspected. To request a Right of Way inspection, contact the Central Engineering Department at (919) 996-3030.

CONTACT	Schedule Online	www.raleighnc.gov/onlinedevelopmentcenter	Rapid Response (automated scheduling)	(919) 857-4412
INFORMATION:	Inspection Info/Scheduling	(919) 516-2500	Right of Way Inspections	(919) 996-3030
	Permit Information	(919) 516-2495	Reinspection with Fee Due	(919) 516-2170

PROJECT: **5005 DENHAM CT**

Required Inspection (permit numbers)	Inspection Rejected / Canceled / Deleted Date(s)	Approved
PLUMBING - ADAMS KIM	796-8409	
FINAL (93519 Alterations/repairs)		3-11-11
BACK-WATER VALVE / SEWER RELEASE		



GENERAL This card must be kept posted in a building card enclosure or construction trailer located in front of the construction site until the Inspections Department approves all phases of the project. All work must conform with the Code of the City of Raleigh and the laws of the State of North Carolina.
It is unlawful to occupy or to permit the occupancy of a building for which a Certificate of Occupancy has not been issued. N.C.G.S. 160A-423



City of Raleigh
Inspections Department



Group Summary

Group: 245336

Trans: 294761

Site Address

5005 DENHAM CT

Property Owner

FITZSIMMONS, LARRY J & KIM W

5005 DENHAM CT


RALEIGH NC 27613-7818

To help us serve you better, the Inspections Department is providing you with a listing of inspections required for your project. Please request these inspections in the order presented. The contractor performing the work must make the request for inspection the business day prior to the day requested. To request an inspection, please visit our online development website at www.raleighnc.gov/onlinedevelopmentcenter, call the automated Rapid Response line at (919) 857-4412, or call (919) 516-2500 to speak to the Construction Division. Please be prepared to provide your permit number for the requested inspection. If your project includes driveway, sidewalk or utility stub installation, call the City of Raleigh Public Works Dept at (919) 890-3030 to request these inspections. Additional notes of importance are printed on the permits. Refer to your Inspections card for the name of your Inspectors.

Required Inspections

Permit Type	Permit #	Inspection Required	Work Type
Plumbing	# 93519	FINAL	Alterations/repairs

PLEASE share above inspections information with all contractors.



**City of Raleigh
Inspections Department**

Plumbing Permit



Transaction #: 294761

Group #: 245336

Inspector: ADAMS KIM

Permit #: 93519

ADDRESS: **5005 DENHAM CT**

Subdivision: HARRINGTON GROVE

Lot Number: NC PIN: 0779504254 000

Real Estate ID: 0161490

Conditions/Comments:

City Limits: YES Hist. Landmark: Hist. Dist:

Authorized Work: REPLACING PIPES WITH POLY

Work Type: Alterations/repairs

Permit Approved by: SPRINGB

Property Owner:

Contractor: *State License Number:*

FITZSIMMONS, LARRY J & KIM W
5005 DENHAM CT
RALEIGH NC 27613-7818

FITZSIMMONS, LARRY J & KIM W

Building Contractor:

Permit Details

Permitted Sq Ft:

Sq Ft for calculation: 0 SQ FT

Bldg Total Stories:

Total Dwelling Units:

Total Handicap Units:

Sprinkler/Standpipe: NO FIRE SUPPRESSION EQUIPMENT

Census Code: 434 / ADDITION/ALTERATION RESIDENTIAL BLDG

Zoning: RESIDENTIAL-6

Basement Occp: UNKNOWN

Min Housing:

Floodplain: NO

Water:

Sewer:

Parc Land Use (new): 110 / SINGLE FAMILY

Parc Land Use (ex): 110 / SINGLE FAMILY

Bldg Land Use (new): 110 / SINGLE FAMILY

Bldg Land Use (ex): 000 / UNKNOWN

Unit Land Use (new): /

Unit Land Use (ex): /

Class Const (new):

Class Const (ex):

Class Occp (new):

Class Occp (ex):

2009 CODE

V B

2009 CODE

RESIDENT 3 SFD/DUP

Permit Fee:

\$74.00

TOTAL FEE PAID:

\$74.00

Cashier: SPRINGB

Date Issued: 2/18/2011

Payment Receipt #: 252175

DO NOT REMOVE THIS NOTICE

City of Raleigh Inspection Notice

Permit Details

Permit Number: PL-93519-F

Inspection Type: FINAL

Project Address: 5005 DENHAM CT

Inspection Result: Partially Approved on 3/1/2011 11:10:39 AM

Segment Name: 132011

Code:

See inspector comments

Inspector Comments: SEAL AROUND WATERLINES IN BOTTOM PLATE IN HALF-BATH

Code: 305.8

305.8 Protection against physical damage.

In concealed locations where piping, other than cast iron or galvanized steel, is installed through holes or notches in studs, joists, rafters or similar members less than 1.5 inches (38 mm) from the nearest edge of the member, the pipe shall be protected by shield plates. Protective shield plates shall be a minimum of 0.062 inch thick (1.6 mm) steel, shall cover the area of the pipe where the member is notched or bored, and shall extend a minimum of 2 inches (51 mm) above and below top plates and below bottom plates.

Inspector Comments: ON CEILING JOIST --- AND TOP-PLATE AND BOTTOM PLATE IN HALF BATH PLATES WILL NEED TO BE 5"X8"---

Inspector: ADAMS, KIM

Phone: (919) 796-8409

Email: kim.adams@cityofraleigh.nc.us

Construction Office Phone: (919) 516-2500

Engineering Office Phone: (919) 890-3030

Fire Marshal Office: (919) 831-6392