Table 401.9
ENERGY EFFICIENCY CERTIFICATE

Build, Permit Holder, or Registered Design Professional
Print Name:

Signature:

Property Address: 1903 ROTHESAY DRIVE

Date:

Insulation Rating - List the value covering the largest area to all that Apply	R-Value
Ceiling/Roof:	R- 38
Wall:	R- 15
Floor:	R-
Closed Crawl Space Wall:	R-
Closed Crawl Space Floor:	R-
Slab:	R- 10
Basement Wall:	R-
Fenestration:	
U-Factor	.35
Solar Heat Gain Coefficient (SHGC)	.27
Building Air Leakage	
☑ Visually inspected according to 402.4.2.1 OR	
☐ Building Air Leakage Test Results (Sec. R402.4.2.2) ACH50 [Target: 5.0] OR CFM50/SFSA [Target: 0.30]	
Name of Tester/Company: [redacted] Date: 03/20/20 Phone: 704-[redacted]030	
Ducts:	
Insulation	R- 8
Total Duct Leakage Test Result (Sec. R403.3.3) Circle one: Total Duct Leakage Test (CFM25 Total/100SF) [Target: 5] OR Duct Leakage to outside Test (CFM25 Total/100SF) [Target: 4]	3.14%
Name of Tester/Company: Performance Point, LLC Date: 03/20/20 Phone: 704-563-1030	