Permit Application Status

2020-00002472-26413

You will only be able to view fees or schedule inspections if you are a contact on the permit application.

Summary

Application Number:	2020-00002472-26413
Application Type:	Swimming Pool, Spa & Hot Tub
Application Status:	Closed
Property Owner's Full Name:	TRIPLE A HOMES INC
Category of Work:	Other
Description of Work:	Pool 16 X 34
Application Date:	10/14/2020
Issued Date:	10/29/2020
Expiration Date:	12/21/2022
Date Finaled:	06/28/2022

Locations

Locations:	Property 0648546495 Address

5316 MABE DR, HOLLY SPRINGS,
NC 27540

Permits

Permit Number: 2020-00002472-26413

Permit Type: Pool
Permit Status: Finaled
Date Issued: 10/29/2020
Expiration Date: 12/21/2022

Work Items

Description	Units	Quantity
Swimming Pool, Residential	EA	

Submittals

There are no submittals for this permit application.

Reviews

There are no reviews for this permit application, or you are not authorized to view them.

Inspections

Inspection	Outcome	Requested	Scheduled	Date Inspected
Building File Review	Passed	10/14/2020	10/14/2020	10/14/2020
Inspector:	Ricky Parson (919) 557-2915			
Comments:	0 Plan Review by Code Official Building Permit Review OK			
Electrical Rough-in Inspection	Failed	5/7/2021	5/7/2021	05/07/2021

	Inspector: Comments:	Clyde Stephenson (919) 524-2617 32 Electrical Rough In Incorrect Inspection Scheduled Should Be Electrical Ground Work		
Electrical Ground Work Inspection	Failed	5/7/2021	5/7/2021	05/07/2021
	Inspector: Comments:	Clyde Stephenson (919) 524-2617 31 Electrical Ground Work Failed 1- Inspected conduits from pool pump pad to wet niche lighting (2) locations 2- Pool bond minimum (4) points incomplete 3- Pool grid bonding Incomplete Ok to Continue		
Electrical Ground Work Inspection	Passed	6/18/2021	6/18/2021	06/18/2021
	Inspector: Comments:	Andrew Blackmon (919) 208-1472 31 Electrical Ground Work Failed 1- Inspected conduits from pool pump pad to wet niche lighting (2) locations 2- Pool bond minimum (4) points complete 3- Pool grid bonding Complete 4- Lights and handrail bonding complete. Ok to Pour concrete.		
Electrical Rough-in Inspection	Passed	6/18/2021	6/18/2021	06/18/2021
	Inspector: Comments:	Andrew Blackmon (919) 208-1472 32 Electrical Rough In Approved 1- Pool equipment set up beside house and bonded.		
Building Final Inspection	Failed	10/21/2021	10/21/2021	10/21/2021
	Inspector: Comments:	Andrew Blackmon (919) 208-1472 21 Building Final		

Corrections:	
Correction 1:	Building Code Comment
Status:	Resolved
Date Status Changed:	06/28/2022
Comments:	On both gates leading into back yard: Gates must be self-latching and self-closing. Gates must have release mechanism of self-latching device located pool side of gate at least 3" from top of gate. Release mechanism shall be at least 54" from bottom of gate.
Correction 2:	Building Code Comment
Status:	Resolved
Date Status Changed:	06/28/2022
Comments:	Need homeowner to verify alarm at back door leading out to pool.

Electrical Final Inspection	Passed	10/21/2021	10/21/2021	10/21/2021
Inspector:	Andrew Blackmon (919) 208-1472			
Comments:	34 Electrical Final			
Building Final Inspection	Passed	6/28/2022	6/28/2022	06/28/2022
Inspector:	Clyde Stephenson (919) 524-2617			

Conditions

There are no conditions for this permit application, or you are not authorized to view them.

Related Permit & Planning Applications

There are no related items for this permit application.

Powered by CityView