OPERATION PERMIT

Franklin County Health Department
107 Industrial Drive
Louisburg, NC 27549
Phone:

For Office Use Only

*CDP File Number: 395958 - 1
County ID Number:
Evaluated For: NEW

Property Owner: ASHTON RALEIGH RESIDENTIAL
Owner Address: 900 RIDGEFIELD DR ST 335

City: RALEIGH
State/Zip: NC/ 27609
Phone #:
Address: 45 SCOTLAND DR
YOUNGSVILLE, NC 27596
Road #:
Township:
Subdivision:
Phase : NEW Lot:

Structure: SINGLE FAMILY
# of Bedrooms: 4
# of People: 5
Water Supply: NEW WELL
Saprolite System?: ☐ Yes ☒ No
Pump Required?: ☐ Yes ☒ No
Design Flow: 480
System Classification/Description: TYPE II A. CONV SYSTEM (SINGLE-FAMILY OR 480 GPD OR LESS)

Installer: DBS

Certification #:

Specific System Installed: EZFLOW EZ 1203H-GEO

STB: 502

PT: 237

Septic Tank Date: 07/06/2023

Pump Tank Date: 06/18/2023

Comments:

This system has been installed in compliance with applicable NC General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.

PERMIT CONDITIONS:

I. Performance: System shall perform in accordance with Rule .1961.

II. Monitoring: As required by Rule .1961.

III. Maintenance: Ground absorption sewage treatment and disposal systems shall be checked, and the contents of the septic tank removed, periodically from all compartments, to ensure proper operation of the system. The contents shall be pumped whenever the solids level is found to be more than 1/3 of the liquid depth in any compartment.

Other:

Subsurface Operator Required: ☐ Yes ☒ No

If yes, see attached sheet for additional operation conditions, maintenance and reporting.

Operation:

Other:

Authorized State Agent: Jones, Lori

Date of Issue: 09/06/2023

Owner/Applicant: _____

June 30

10:30

Pump Lek needs pmt. 9-1-23 Lot 38

Franklin County
NORTH CAROLINA

Parcel ID: 048699

File # 395958 PIN#

Property Address: 45 Scotland Dr. Yngs

Applicant or Owner Name: Ashton Raleigh Resid

Environmental Health Septic/Well Permit Diagram

Building permits cannot be issued nor should construction begin without Construction Authorization issuance.

(1) Septic Improvement Permit (1) Septic Construction Authorization (CA) ( ) CA Reissue** ( ) As Built

(1) Well Construction Authorization ( ) Additional Diagram/Specifications Attached

Diagram Date:** 6-30-2023 **EHS:** Lori Jones

****Any previously dated CA diagram is revoked and/or invalid. Confirm this is the valid diagram for the site before beginning any construction.**

Installation/grouting inspections may be scheduled the day before, or, the day of installation until 9am by contacting the Environmental Health office at 919 496 8100. A revisit fee may apply if installation is not ready for inspection at the time requested. *Septic Operations Permits* will be issued after installation is approved, all permits conditions are met, and any outstanding fees are paid. *Well Certificate of Completion* will be issued after well head approval, all permit conditions are met, and any outstanding fees are paid.

Septic Tank 1000 Pump Tank 1000 Drainfield 3'x440 Type System Pump/ manifold Accepted Max Trench Depth 22" LTAR .275

Septic Contractor DBS Septic/Pump tank dates 7-6-23/6-18-23 Pump fee? NO YES pd paid

Well Contractor _____ Well Grout date: _____ 502/237 PP

Bedrooms: 4

* Drawing submitted by Soil Scientist

Please install septic system in accordance with attached design sheet(s) submitted by CCSC. Respect all setbacks.

> Enclosures / Attachments

EZ Flow

SJE Remous Ashlynd

✓ 3rd - 5'7½" Line

✓ Manifold

Water on/off

Alarm ✓