Construction Authorization

Franklin County Health Department
107 Industrial Drive
Louisburg, NC 27549
Phone:

For Office Use Only

*CDP File Number: 469733 - 1
County ID Number:
Evaluated For: NEW

PERMIT VALID UNTIL: 04/24/2031
☐ Open Pump System Sheet

Applicant:	John Jenkins
Address:	8608 Windsong Valley Dr
City:	Wake Forest
State/Zip:	NC 27587
Phone #:	cell :(919) 455-6784

Property Owner:	John Jenkins
Address:	8608 Windsong Valley Dr
City:	Wake Forest
State/Zip:	NC, 27587
Phone #:	cell :(919) 455-6784

Property Location & Site Information

Address/Road #: 806 NC 98 Highway West Bunn, NC 27508
Subdivision: NULL Phase: NEW Lot:

Directions:
806 NC 98 Highway West Bunn NC 27509

Structure: SINGLE FAMILY
# of Bedrooms: 3
# of People: 6
*Water Supply: NEW WELL

System Specifications

Usable Soil Depth: 42
Design Flow: 360
Soil Application Rate: 0.3000
*System Classification/Description: Type IIIg - Other Non-Conventional Systems
*Proposed System: 25% REDUCTION

Minimum Trench Depth: ____ Inches
Maximum Trench Depth: 30 Inches
Minimum Soil Cover: ____ Inches
Maximum Soil Cover: ____ Inches
*Distribution Type: GRAVITY - PARALLEL (eq. d-box)

Nitrification Field: ____ Sq. ft.
No. Drain Lines: 4
Total Trench Length: 300 ft.
Trench Spacing: 9 - ____
Trench Width: 3 - ____
Aggregate Depth: ____ inches

○ Inches O.C. ⊗ Feet O.C.
○ Inches ⊗ Feet

Septic Tank: 1,000 Gallons
Pump Required: ○ Yes ⊗ No ○ May Be Required
Pump Tank: ____ Gallons
Grease Trap: ____ Gallons
Septic Tank Installer Grade Level Required: ○ I ○ II ○ III ○ IV

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements.

***Permit Conditions:**
John Davis submitted complete soil work also; confirmed by EHS

The Authorization for Wastewater System Construction shall be valid for a period equal to the period of validity of the Improvement Permit and may be issued at the same time the Improvement Permit issued (NCGS 130A-336(b)). If the installation has not been completed during the period of validity of the Construction Permit, the information submitted in the application for a permit or Construction Authorization shall become invalid , and may be suspended or revoked (.0204(k)(1)). The person owning or controlling the system shall be responsible for assuring compliance with the laws, rules, and permit conditions regaurding system location, installation, operation, maintenance, monitoring, reporting and repair (per rule .0301((a)).

Authorized State Agent: Jones, Lori
Date of Issue: 04/24/2026

****Site Plan/Drawing attached.****
Total Time : (HH:MM) ____

○ Hand Drawing ○ Import Drawing