RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources- Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2476

1. WELL CONTRACTOR:
Jerry Ball
Well Contractor (Individual) Name
Jerry Ball Well Drilling
Well Contractor Company Name
STREET ADDRESS 352 Moulton Rd
Louisburg N.C 27549
City or Town State Zip Code
919-497-5491
Area code Phone number

2. WELL INFORMATION:
SITE WELL ID #(if applicable)
STATE WELL PERMIT#(if applicable) 469733
DWQ or OTHER PERMIT #(if applicable)
WELL USE (Check Applicable Box). Residential Water Supply ☑
DATE DRILLED 9-8-26
TIME COMPLETED 9-8-26 AM ☐ PM ☑

3. WELL LOCATION:
CITY COUNTY Franklin
806 NC Hwy 98 West
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code)
TOPOGRAPHIC / LAND SETTING:
☐ Slope ☐ Valley ☐ Flat ☑ Ridge ☐ Other
(check appropriate box)
LATITUDE 35°57.581'
LONGITUDE 78°16.458'
May be in degrees, minutes, seconds or in a decimal format
Latitude/longitude source: ☑ GPS ☐ Topographic map
(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

4. WELL OWNER
OWNER'S NAME John Jenkins
STREET ADDRESS 806 NC Hwy 98 West
Bunn NC
City or Town State Zip Code
919-455-6784
Area code - Phone number

5. WELL DETAILS:
a. TOTAL DEPTH: 160'
b. DOES WELL REPLACE EXISTING WELL? YES ☐ NO ☑
c. WATER LEVEL Below Top of Casing 18 FT
(Use "+" if Above Top of Casing)
d. TOP OF CASING IS 1 FT Above Land Surface*
*Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118
e. YIELD (gpm) 20 METHOD OF TEST blow down

1. DISINFECTION: Type Chlorine Amount 16 oz

8. WATER ZONES (depth)
From 66 To 10GPM From To
From 139 To 10GPM From To
From To From To

6. CASING:

	Depth		Diameter	Thickness/ Weight	Material
From +1	To 32	Ft	6"	SDR21	PVC
From	To	Ft.			
From	To	Ft.			

7. GROUT:

	Depth		Material	Method
From 0	To 20	Ft	Bentonite	Poured
From	To	Ft.		
From	To	Ft.		

8. SCREEN:

	Depth		Diameter	Slot Size	Material
From	To	Ft.	in.	in.	
From	To	Ft.	in.	in.	
From	To	Ft.	in.	in.	

9. SAND/GRAVEL PACK:

	Depth		Size	Material
From	To	Ft.		
From	To	Ft.		
From	To	Ft.		

10. DRILLING LOG

From	To	Formation Description
0	3	Soil
3	26	Clay
26	160	Granite

11. REMARKS:

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER

Jerry Ball — 9-8-26
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

Jerry Ball
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt.
1617 Mail Service Center – Raleigh, NC 27699-1617 Phone No. (919) 733-7015 ext 568.

Form GW-1b
Rev. 7/05